



BHARAT TEST HOUSE

Office : 109, Anupam Bhawan, Azadpur Complex, Delhi-110033
Lab. : 454/2, Timber Market, Near Azadpur Chowk, Delhi-110033
Tel.: 27672629, 27681204, 27675696 Telefax : 91-11-27681204
E-mail : bharatatesthouse@yahoo.com



BS EN ISO 9001 : 2000
Certificate No. FS 69906

TEST CERTIFICATE

Test Certificate No. : 200701290162

Issue Date : 29/01/07

Issued To : M/s Savvir Faire Merchandising Co. Job Order No. : BTH/R/0151

C - 195, Pushpanjali Enclave,
Pitam Pura, Delhi - 110034.

Ref. No. : Nil

Date : 25/01/07

Date of Sample Receipt : 25/01/07

Sample Deposited By : Party

Page ...1... of ...1....

Sample Particulars : Sample of P. P. R. Pipe


Protocol Used : IS : 14885


S.No. Test Conducted

Test Result

1. Hydraulic Pressure Test
Bursting Strength at 50 Kg/cm²

No Leakage is Observed
(Passes the Test)

Checked by 


Authorised Signatory
K.K. JUNEJA
HOD

1) The above results are related only to the tests performed on the sample. Endorsement of product is neither inferred nor implied. (2) This report is not to be reproduced wholly or in part & can not be used as an evidence in the court of law & should not be used in any advertising media without our special permission in writing. (3) Samples will be destroyed after 15 & 30 days from the date of reporting unless otherwise specified. (4) Total liability of our Test House is limited to the invoiced amount. (5) Report refers to the sample drawn by Bharat Test House unless mentioned otherwise.

BS EN ISO 9001 : 2000 CERTIFIED